

Code	Label	Value1	Value2	Value3	Value4	Value5	
2	Tag	DPT-203A					
2	Device ID	2424380					
2	Activity Date	9/11/2008 11:20					
1	Calibrator Model	MFT 4010 -01-1-00					
1	Calibrator SN	962540-J34					
1	Calibrator Calibration Date	11/14/2008 11:36					
1	Sensor SN	60106145					
1	Sensor Model	DDN0400					
2	Input	0.000 to 99.930 InH2O					
2	Output	4.000 to 20.000 mA					
3	Service Note						
4	As Found	Test Point	Input	Output	Expected Output	Error (%)	
4			1	-0.01	4.146	3.998	0.923
4			2	33.31	9.462	9.333	0.804
4			3	66.61	14.787	14.665	0.762
4			4	99.92	20.103	19.998	0.654
4	As Left	Test Point	Input	Output	Expected Output	Error (%)	
4			1	-0.01	4.003	3.998	0.029
4			2	33.32	9.337	9.335	0.013
4			3	66.61	14.662	14.665	-0.019
4			4	99.93	19.993	20	-0.044